



CIMEC TECHNOLOGIES PRIVATE LIMITED

CIN : U29100GJ2011PTC064482

ISO 9001 : 2015 Certified Company

Regd. Office & Lab 23 / H Meldi Estate, Nr. Gota Railway Crossing, Gota, Ahmedabad - 382481, Gujarat **P** +91 2717 241209 **E** info@cimec.in
Technical Queries +91 99250 28369 **Customer Care** +91 75679 55968

CIMEC®

www.cimec.in

TEST REPORT

Format No. : QF/7.8/01

ULR : TC554926000000468F

Customer's Details: Rebar Connect Solution Pvt Ltd

A Top Power, Near Ravki Makhavad Main Road,
Rajkot, Gujarat

Report No. : CT/2601050061
Issue Date : 06/01/2026
Commencement Date : 05/01/2026
Completion Date : 05/01/2026
Page No. : 1/1

Your Ref. No. : Your Letter Date 05/01/2026

Particulars of Sample (as declared by party)

Material Name and Particulars : Coupler

Size : Dia: 25mm, Sampling : Done By Customer,

Date of Receipt : 05/01/2026

Sample Qty : 1Nos.

Any other information

Name of Client : Deep Radadiya

Name of Consultant/PMC/TPI : Not Declared

Name of Contractor/Agency : Rebar Connect Solution Pvt Ltd

Name of Witness : Not Applicable

Name of Work/Project : Not Declared

Sr. No.	Test Parameter	Unit	Test Method	Specified Requirements As per BS EN 10277	Observed Values
Group Name : Metal & Alloys					
Discipline : Chemical					
1	Carbon	%	ASTM E415-21	0.40 - 0.45	0.41
2	Sulphur	%	ASTM E415-21	0.060 Max.	0.025
3	Phosphorus	%	ASTM E415-21	0.060 Max.	0.028
4	Manganese	%	ASTM E415-21	0.70 - 0.90	0.75
5	Silicon	%	ASTM E415-21	0.15 - 0.35	0.22

Remarks : Nil

****End of Report****

REVIEWED & AUTHORIZED



SEVAN RATHWA
Lab Incharge

(Authorised Signatory)

CIMEC TECHNOLOGIES PVT. LTD.

NOTE: The above results are related only to the test/s performed on the sample, Endorsement of the product is neither inferred nor implied. This report is not to be reproduced wholly or in part & forbidden to be used as evidence in the court of law & ought not to be used in any advertising media without special permission in writing from Managing Director CIMEC Technologies Pvt. Ltd. Any discrepancies observed in the test report shall be brought to the notice of the Laboratory within one week. Total Liability of CIMEC Technologies Pvt. Ltd. is limited to the invoices amount only. The general condition of service is overleaf.