



CIMEC TECHNOLOGIES PRIVATE LIMITED

CIN : U29100GJ2011PTC064482

ISO 9001 : 2015 Certified Company

Regd. Office & Lab 23 / H Meldi Estate, Nr. Gota Railway Crossing, Gota,
Ahmedabad - 382481, Gujarat **P** +91 2717 241209 **E** info@cimec.in
Technical Queries +91 99250 28369 **Customer Care** +91 75679 55968

CIMEC®

www.cimec.in

TEST REPORT

Format No. : QF/7.8/01

ULR : TC554926000000466F

Customer's Details: Rebar Connect Solution Pvt Ltd

A Top Power, Near Ravki Makhavad Main Road,
Rajkot, Gujarat

Report No. : CT/2601050059
Issue Date : 06/01/2026
Commencement Date : 05/01/2026
Completion Date : 05/01/2026
Page No. : 1/1

Your Ref. No. : Your Letter Date 05/01/2026

Particulars of Sample (as declared by party)

Material Name and Particulars : Coupler

Size : Dia: 16mm, Sampling : Done By Customer,

Date of Receipt : 05/01/2026

Sample Qty : 1Nos.

Any other information

Name of Client : Deep Radadiya

Name of Consultant/PMC/TPI : Not Declared

Name of Contractor/Agency : Rebar Connect Solution Pvt Ltd

Name of Witness : Not Applicable

Name of Work/Project : Not Declared

Sr. No.	Test Parameter	Unit	Test Method	Specified Requirements As per BS EN 10277	Observed Values
Group Name : Metal & Alloys					
Discipline : Chemical					
1	Carbon	%	ASTM E415-21	0.40 - 0.45	0.43
2	Sulphur	%	ASTM E415-21	0.060 Max.	0.042
3	Phosphorus	%	ASTM E415-21	0.060 Max.	0.020
4	Manganese	%	ASTM E415-21	0.70 - 0.90	0.81
5	Silicon	%	ASTM E415-21	0.15 - 0.35	0.27

Remarks : Nil

****End of Report****

REVIEWED & AUTHORIZED



SEVAN RATHWA
Lab Incharge
(Authorised Signatory)
CIMEC TECHNOLOGIES PVT. LTD.

NOTE: The above results are related only to the test/s performed on the sample, Endorsement of the product is neither inferred nor implied. | This report is not to be reproduced wholly or in part & forbidden to be used as evidence in the court of law & ought not to be used in any advertising media without special permission in writing from Managing Director CIMEC Technologies Pvt. Ltd. | Any discrepancies observed in the test report shall be brought to the notice of the Laboratory within one week. | Total Liability of CIMEC Technologies Pvt. Ltd. is limited to the invoices amount only. | The general condition of service is overleaf.